

Light Emission Distribution Laboratory

Division of Photometry & Electrical Testing Pty. Ltd ABN 11 166 255 134
Unit 4, 140 George St. Hornsby NSW 2077 Australia
Ph: +61 2 9476 3097 E: sales@ledlab.com.au



Accredited for
Compliance
with ISO/IEC
17025
Accreditation
No. 19541

PHOTOMETRIC TEST REPORT No. 201143PH


Date: 23rd November 2020

Client: Offspring Profiles Ltd.
Address: 40 Austin Street, Onekawa, Napier NZ.
Contact: Robin Campbell


Luminaire: Bob Each Way 65

Catalogue No. BEW65

Description: Offspring Profiles LED Extrusion BEW65
with Opal diffuser (Direct) and Clear Diffuser (Indirect)



Direct



Indirect

Optical System: Offspring Profiles Super Series-26W-4000K
(Direct), Super Series 14W-4000K (Indirect)

Control Gear: Lisun DC Series DC3010 24VDC Power Supply

Test Specification:

The luminaire was tested in accordance with the procedures given in IES LM79-19, "Optical and electrical measurements of Solid-State Lighting Products" using the **absolute** method.


Results:

When tested at an ambient of 25°C at a supply voltage of 24VDC, the luminaire consumed 0.858A and 20.59W. That is, Lamp Circuit Power (LCP), which includes power supply losses, is 20.59W.

The Total Luminous Flux was measured as 1368 Lumens.

The Correlated Colour Temperature was measured as 4086K average.

Luminous Intensity Distribution (I-TABLE) is given on Page 5.



C0-C180° Vertical Plane
C90-C270° Vertical Plane

Tested by: B. Real/ J. King on 16th November 2020

Authorised Signatory: _____

A. Yetendje



Test Configuration

The luminaire was photometered in IESNA Horizontal – Vertical Reference angles such that:

- The luminaire was mounted with photometric centre aligned with photometric zero (in the direction of nadir), centred on the light emitting area.
- The supply wires were located on the 0° Horizontal angle, photometric horizontal, in the zero-degree photometric plane.
- In accordance with CIE S 025/E:2015 Clause 5.3.2 midway between Direct and Indirect Diffusers was co-incident with centre of the goniophotometer.
- The long dimension of the optical opening in the direction of the H= 0° - 180° Plane.
- The photometric test distance of 9.85m, is referenced to the photometric centre of the luminaire and the photocell.

Due to the Type B mounting arrangement, a correction factor to achieve correct orientation was determined but not applied as it was less than 0.5% and accounted for in the Uncertainty Budget. Should these Uncertainties be required contact LEDLab.


Test Procedures and Equipment

Calibration report:	200627CAL using N.M.I. report RN 181690 on standard lamp M14192
Technical Procedure:	P113 & P118
Angular Resolution:	Test Configuration and issued .ies file C Plane Interval 15 Deg Gamma Angle Interval 1.0 Deg Abbreviated Test Report File (I-Table) C Plane Interval 15 Deg Gamma Angle Interval 5.0 Deg
Software:	Lisun LSG-1800B
Obstructions:	None
Lab. Book Page:	PH4/1762
Primary Orientation Correction:	1.0
Colour correction:	1.028
Goniophotometer:	Lisun Electronics Model LSG-1800B, Serial No. GSGHF070010.
Photocell:	Lisun Electronics Detector Serial No. 330220-1
Lux meter:	Lisun Electronics Model PM 400, Serial No. GSRXK090021
Lux meter integration time (PLC):	5
Power meter:	Lisun Electronics Model RT-200, Serial No. GSXY0100021
Power meter integration time (s):	0.5
Luminaire thermometer:	AMA 1362983 0.1°C Serial No 526,10942
Temperature Data Logger:	Lisun TMP-8 Multiplex Serial No GSJWM010028
Auxiliary Photocell:	Delta Ohm HD 2102.1 & LP471PHOT

TEST REPORT and IES file archive

The data files for this report are contained in the *archive file: 201143PH.zip*

IES file: 201143PH.IES Document File: 201143PH.pdf









Direct



Indirect



ANSI/IES TM-30-18 COLOR RENDITION REPORT



Notes:

x 0.3755
y 0.3698
u' 0.2247
v' 0.4977

CIE 13.3-1995
(CRI)

R_a 96
R_g 84



PHOTOMETRIC TEST REPORT No. 201143PH

Date: 23rd November 2020

LUMINOUS INTENSITY DISTRIBUTION (I-Table) - cd																										
Vertical	Horizontal Angle (H Plane) - Degrees																									
Angle (V)																										
Degrees	0	15	30	45	60	75	90	105	120	135	150	165	180	195	210	225	240	255	270	285	300	315	330	345	360	
0	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	225	
5	224	224	224	224	224	224	223	224	224	224	224	224	224	224	224	224	224	224	224	224	224	224	224	224	224	
10	221	221	221	221	221	221	221	221	221	221	221	221	220	221	221	221	221	221	221	221	221	221	221	221	221	
15	216	215	216	215	216	216	216	216	216	216	216	216	216	216	216	216	216	216	215	216	215	216	215	216	216	
20	209	208	209	208	209	208	209	208	209	209	210	209	209	210	209	210	209	209	208	209	208	209	209	209	209	
25	201	200	201	199	200	199	199	199	200	200	201	201	200	201	200	201	200	200	198	200	199	200	199	200	201	
30	190	189	190	188	189	187	187	187	189	189	191	190	190	191	190	190	188	189	187	189	188	190	189	190	190	
35	178	177	178	175	175	173	174	173	175	176	179	178	178	179	177	178	175	175	174	175	175	177	176	178	178	
40	165	164	164	161	161	158	161	159	161	161	165	165	164	166	164	164	161	161	159	161	161	162	161	164	165	
45	151	149	149	145	144	141	142	142	144	146	150	150	150	152	149	148	144	145	142	144	143	148	148	150	151	
50	135	133	132	127	126	123	124	123	127	128	133	134	134	135	132	131	126	126	123	126	125	130	131	134	135	
55	117	116	114	108	107	104	105	104	108	110	115	117	116	118	114	112	107	107	104	106	106	111	112	116	117	
60	99	97	94	88	87	83	85	84	88	90	95	98	98	99	94	92	87	87	84	86	86	91	93	98	99	
65	80	77	74	68	66	63	64	63	67	69	75	78	79	80	74	71	66	65	63	65	65	70	73	78	80	
70	60	57	53	46	45	41	42	42	45	48	55	58	59	59	53	50	44	45	42	44	43	49	51	58	60	
75	40	37	33	26	24	21	22	21	25	27	33	38	39	39	32	29	24	24	22	23	23	28	31	38	40	
80	21	18	13	7	6	6	7	6	6	9	14	18	20	20	13	10	7	7	7	7	6	10	12	18	21	
85	5	3	0	0	0	1	1	1	1	1	0	2	4	3	0	1	1	2	2	2	1	0	0	2	5	
90	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
95	0	0	0	0	0	0	0	0	0	0	0	2	1	1	0	0	0	0	0	0	0	0	0	0	0	
100	10	8	9	2	1	1	2	1	2	4	12	14	13	13	9	4	1	1	1	0	1	3	6	10	10	
105	29	25	23	15	12	8	10	9	15	19	29	34	33	33	23	17	14	12	8	10	13	15	19	28	29	
110	56	51	48	31	26	24	25	25	29	37	57	63	62	63	46	32	26	26	26	25	24	29	40	55	56	
115	89	83	84	60	47	40	41	41	52	69	93	96	95	97	80	58	42	39	36	37	40	52	73	88	89	
120	122	115	118	104	85	69	70	72	92	114	129	130	129	130	119	97	70	62	56	60	66	91	110	121	122	
125	153	146	149	146	139	119	122	123	146	154	160	160	161	161	155	141	113	100	91	98	110	135	146	153	153	
130	182	175	175	173	178	172	174	176	186	184	187	189	189	189	184	179	161	151	140	148	156	172	176	180	182	
135	209	202	202	199	204	206	211	208	212	208	213	214	215	214	210	208	199	195	188	193	196	203	203	205	209	
140	231	225	226	222	225	225	230	230	233	231	235	237	236	236	234	232	228	227	223	225	225	227	226	229	231	
145	250	245	248	244	246	245	250	249	253	251	257	255	254	257	253	253	249	250	247	248	247	249	247	251	250	
150	267	264	268	266	266	265	267	267	271	271	273	271	270	273	273	271	268	268	266	266	266	266	267	269	267	
155	281	278	281	282	284	283	285	284	288	286	286	284	284	286	291	288	284	284	282	283	282	284	286	282	281	
160	293	290	293	292	295	296	298	297	298	296	296	296	296	296	300	303	301	300	297	298	300	300	296	293	293	
165	302	299	302	301	302	303	304	303	305	303	305	304	304	304	306	308	309	311	311	310	309	306	303	303	302	
170	308	306	309	308	309	309	310	309	311	310	311	311	311	310	312	312	313	314	314	313	312	311	310	309	308	
175	315	312	314	313	314	314	316	315	316	315	316	316	315	314	316	315	315	315	315	315	316	315	316	316	315	
180	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	315	